



54 Audia Court, Unit 2
Concord, ON L4K 3N5
(905)-738-1400

Request For Information 24-257-001

Apr 7, 2025

Project Name

140 LAKE DRIVE EAST, KESWICK

Project Address

140 LAKE DRIVE EAST, KESWICK

To

Name

Tyler Baker

Company

140 LAKE DRIVE EAST

Email

TylerBaker@boltdevelopments.com

Address

From

Name

Marc Rossy

Company

Consult Mechanical Inc.

Email

marc@consultmechanical.com

Address

54 Audia Court, Unit 2 Concord, ON L4K 3N5

Title

Lennox Air Handling Units

SCHEDULE IMPACT

No

COST IMPACT

Probable

RETURN BY

Apr 14, 2025

Information Requested

Lennox does not have hydronic coils in their new air handling units.

We can install external hot water coils as an option. Please advise?