



54 Audia Court, Unit 2  
Concord, ON L4K 3N5  
(905)-738-1400

## Request For Information 24-257-002

Apr 7, 2025

Project Name

140 LAKE DRIVE EAST, KESWICK

Project Address

140 LAKE DRIVE EAST, KESWICK

### To

Name

Tyler Baker

Company

140 LAKE DRIVE EAST

Email

TylerBaker@boltdevelopments.com

Address

### From

Name

Marc Rossy

Company

Consult Mechanical Inc.

Email

marc@consultmechanical.com

Address

54 Audia Court, Unit 2 Concord, ON L4K 3N5

---

### Title

Lennox Air Handling Units

### SCHEDULE IMPACT

No

### COST IMPACT

Probable

## RETURN BY

Apr 14, 2025

### Information Requested

Lennox does not have hydronic coils in their new air handling units.

We can install external hot water coils as an option. Please advise?