



54 Audia Court, Unit 2  
Concord, ON L4K 3N5  
(905)-738-1400

## Request For Information 24-229-005

Nov 7, 2024

Project Name

2299 DUNDAS - SHELTER RENOVATION

Project Address

2299 Dundas Street West, Toronto, ON

### To

Name

Paddy Delvin

Company

ROSSCLAIR CONTRACTORS INC.

Email

paddyd@rossclair.ca

Address

59 COMSTOCK ROAD, UNIT 1 TORONTO, ON M1L 2G6

### From

Name

INZAMAN KHAN

Company

Consult Mechanical Inc.

Email

inzaman@consultmechanical.com

Address

54 Audia Court, Unit 2 Concord, ON L4K 3N5

---

### Title

SI-11 - Beam Elevation Conflict

### SCHEDULE IMPACT

No

### COST IMPACT

Probable

## RETURN BY

Nov 7, 2024

### Information Requested

It has been identified that the current elevation of the beam conflicts with the storm piping design. Specifically, most of the piping will not be feasible to install without coring through the beam. The issue was previously discussed on-site. However, this conflict is not reflected in the current design drawing. Please review the clouded areas in the drawing where pipe must pass through the beam or reroute to avoid clash and advise !