



54 Audia Court, Unit 2
Concord, ON L4K 3N5
(905)-738-1400

Request For Information 24-229-013

Apr 22, 2025

Project Name

2299 DUNDAS - SHELTER RENOVATION

Project Address

2299 Dundas Street West, Toronto, ON

To

Name

Paddy Devlin

Company

ROSSCLAIR CONTRACTORS INC.

Email

Address

59 COMSTOCK ROAD, UNIT 1 TORONTO, ON M1L 2G6

From

Name

ADNAN KHAN

Company

Consult Mechanical Inc.

Email

adnan@consultmechanical.com

Address

54 Audia Court, Unit 2 Concord, ON L4K 3N5

Title

Addition of hub drain in meter room in basement

SCHEDULE IMPACT

Probable

COST IMPACT

Probable

RETURN BY

May 6, 2025

Information Requested

During the inspection, the plumbing inspector requested the addition of a funnel floor drain to accommodate the sprinkler blow-off and meter drains in the meter room. This drain is not shown on the current contract drawings.

Since the drain will need to be sized based on the anticipated flow from the sprinkler blow-off, we require further direction and request for clarification whether we should proceed with the installation of the funnel floor drain as per the inspector's request?

If so, can you provide guidance on the required sizing and location of the drain? can you issue a drawing to reflect this change?

Attachments

1. [M-101-Basement-plumbing-layout-snip.pdf](#)
2. [M-101-Basement-plumbing-layout.pdf](#)