



54 Audia Court, Unit 2
Concord, ON L4K 3N5
(905)-738-1400

Request For Information 23-214-028

May 23, 2025

Project Name

CHRIS GIBSON REC CENTRE

Project Address

125 McLaughlin Rd N, Brampton, ON, L6X 1N9

To

Name

Ashish Singla

Company

RAFAT GENERAL CONTRACTOR INC.

Email

asingla@corebuildconstruction.com

Address

8850 GEORGE BOLTON PKWY BOLTON, ON L7E 2Y4

From

Name

PAUL LEDDY

Company

Consult Mechanical Inc.

Email

paul.l@consultmechanical.com

Address

54 Audia Court, Unit 2 Concord, ON L4K 3N5

Title

Questions with Chilled Water

SCHEDULE IMPACT

Probable

COST IMPACT

Probable

RETURN BY

May 30, 2025

Information Requested

The CWS and CWR are only shown in the plan view for a small section near the new change rooms, but piping and sleeves are required for AHU-8.

DHU-1 shows a CWS and CWR on the roof plan; however on the schematic drawings it does not require them.

The schematic indicates that AHU-8 HWS and HWR supply ERV-3, but the plan drawings show this connection coming from AHU-4.