

## **Request For Information** 23-214-030

Jun 27, 2025

Project Name Project Address

CHRIS GIBSON REC CENTRE 125 McLaughlin Rd N, Brampton, ON, L6X 1N9

To From

Name Name

Ashish Singla PAUL LEDDY

Company

RAFAT GENERAL CONTRACTOR INC. Consult Mechanical Inc.

Email Email

asingla@corebuildconstruction.com paul.l@consultmechanical.com

Address

8850 GEORGE BOLTON PKWY BOLTON, ON L7E 2Y4 54 Audia Court, Unit 2 Concord, ON L4K 3N5

Title SCHEDULE IMPACT COST IMPACT

additional Roof Drain Required No Probable

**RETURN BY** Jul 2, 2025

## **Information Requested**

With the need to Rotate the MUA unit due to it being too large to fit on the roof in the orientation shown now clarified

But now the posi slope isn't going to work with the orientation of the unit being moved and it looks like there would be an additional Roof Drain Required