



54 Audia Court, Unit 2
Concord, ON L4K 3N5
(905)-738-1400

Request For Information 23-214-035

Jul 28, 2025

Project Name

CHRIS GIBSON REC CENTRE

Project Address

125 McLaughlin Rd N, Brampton, ON, L6X 1N9

To

Name

Ashish Singla

Company

RAFAT GENERAL CONTRACTOR INC.

Email

asingla@corebuildconstruction.com

Address

8850 GEORGE BOLTON PKWY BOLTON, ON L7E 2Y4

From

Name

INZAMAN KHAN

Company

Consult Mechanical Inc.

Email

inzaman@consultmechanical.com

Address

54 Audia Court, Unit 2 Concord, ON L4K 3N5

Title

Missing roof drain

SCHEDULE IMPACT

Probable

COST IMPACT

Probable

RETURN BY

Jul 29, 2025

Information Requested

Changeroom 151J is missing a roof drain. There is a cut-out in the deck where the drain is intended to be, but it was never installed during the original construction.

This roof drain should be considered an extra to our scope, as it was previously missed when the building was built.

Kindly advise on how you would like us to proceed.