



RAFAT

8850 GEORGE BOLTON PARKWAY, CALEDON, ONTARIO L7E 2Y4

RFI Transmittal No:	
----------------------------	--

Project Name:	Renovation of Chris Gibson Recreation Centre Drive	Project No.	T2023-125
		DATE:	

RFI No:	
----------------	--

Title:	
---------------	--

To:	Patrick Johnson - Contract Administrator (DSA) Vincent Goetz - Senior Assoicate (DSA)
------------	--

Requested by	Consult	Sketch Attached		Total # Pages	
---------------------	---------	------------------------	--	----------------------	--

Description of RFI	
Response Required By	

Date Responded		Sketch Attached		Total # Pages	
-----------------------	--	------------------------	--	----------------------	--

Consultants Response	
-----------------------------	--

Approved/Response d by:	
--------------------------------	--

DSA: see response from Isaiah Littlely from Introba above.

Patrick Johnson / DSA
March 18, 2025



54 Audia Court, Unit 2
Concord, ON L4K 3N5
(905)-738-1400

Request For Information 23-214-022

Mar 10, 2025

Project Name

CHRIS GIBSON REC CENTRE

Project Address

125 McLaughlin Rd N, Brampton, ON, L6X 1N9

To

Name

Ashish Singla

Company

RAFAT GENERAL CONTRACTOR INC.

Email

asingla@corebuildconstruction.com

Address

8850 GEORGE BOLTON PKWY BOLTON, ON L7E 2Y4

From

Name

INZAMAN KHAN

Company

Consult Mechanical Inc.

Email

inzaman@consultmechanical.com

Address

54 Audia Court, Unit 2 Concord, ON L4K 3N5

Title

Backwater valve spec confirmation

SCHEDULE IMPACT

Probable

COST IMPACT

No

RETURN BY

Mar 11, 2025

Information Requested

Please review and confirm attached proposed, or advise on the specs for the backwater valves for drip trays by the old arena and one for the elevator pit.

RMLCOMBO

Mainline Fullport Backwater Valve and Acess Box COMBO

COMBO Clapet Anti-Retour à Passage Intégral pour ligne Principale

avec Boîte d'Accès

RML4963A


Backwater Valve

Clapet Anti-Retour


Protects your building against backup from the municipal sewer system.

Protège votre bâtiment contre le refoulement du systeme d'égout municipal.

- **ABS Construction. 4" DWV Hub inlet & outlets**
Construction en ABS. Connexion 4" DWV à l'entrée et sortie
- **Clear Top for easy visual inspection and cleaning**
Couvercle transparent pour une inspection visuelle et un nettoyage aisé
- **Fullport (Normally Open) Non-Flow Restricting**
Passage intégral (normalement ouvert). Écoulement sans restriction
- **Conforms to National Plumbing Code of Canada**
Conforme au Code national de la plomberie - Canada



For Valve Dimensions see right side panel
Pour Dimensions du Clapet voir le panneau de côté droit



INSTALLED JUST INSIDE FOUNDATION WALL
INSTALLÉ DANS LE MUR DE LA FONDATION



RML2013

Access Box

Boîte d'Accès

Designed to make maintenance of the Mainline Backwater Valve more convenient for the homeowner and contractor alike.

Conçu pour faire l'entretien du Clapet Anti-Retour Mainline plus pratique pour le propriétaire et le contracteur.

- **Sits flush to the floor**
S'affleure au sol
- **Features 2 removable bolts for easy access to Valve**
Dispose de 2 boulons amovibles pour faciliter l'accès au Clapet




Check with your local municipality for possible Backwater Valve incentive programs

Vérifiez auprès de votre municipalité locale pour programmes d'aide financière pour Clapets Anti-Retour

RMLCOMBO

Mainline Fullport Backwater Valve

Clapet Anti-Retour à Passage Intégral pour ligne Principale



Access Box for Mainline Fullport Backwater Valve

Boîte d'Accès pour Clapet Anti-Retour à Passage Intégral pour ligne Principale



Questions? Go to www.osb.ca or contact us toll free at 1.877.314.6040.

Questions? Allez au www.osb.ca ou contactez nous sans frais au 1.877.314.6040.

