



54 Audia Court, Unit 2
Concord, ON L4K 3N5
(905)-738-1400

Submittal 23-214-003

PROJECT NAME	PROJECT ADDRESS	DATE SUBMITTED
CHRIS GIBSON REC CENTRE 23-214	125 McLaughlin Rd N, Brampton, ON, L6X 1N9	Dec 2, 2024
TO	FROM	
Ashish Singla	INZAMAN KHAN	
COMPANY	COMPANY	
RAFAT GENERAL CONTRACTOR INC.	Consult Mechanical Inc.	
EMAIL	EMAIL	
asingla@corebuildconstruction.com	inzaman@consultmechanical.com	
ADDRESS	ADDRESS	
8850 GEORGE BOLTON PKWY BOLTON, ON L7E 2Y4	54 Audia Court, Unit 2 Concord, ON L4K 3N5	

Title

EVP-3/CND-2 R1

Description

The specified unit is based on the refrigerant 410A. This new regulation of using the alternate refrigerant is being enforced 'suddenly' within about 6 months time. Canada had once decided not to follow the US to change the new refrigerant as of January 1 2025, and this decision was reversed within recent few months. At the time of tendering the manufacturer did not have information for the new model yet. The supplier provided the pricing of the unit during tender and assumed the unit would be purchased by September this year but that was not the case so alternate is being proposed with no cost impact.

Package Items

SPEC

SUBSECTION

ITEM

TYPE