



54 Audia Court, Unit 2
Concord, ON L4K 3N5
(905)-738-1400

Submittal 23-214-004

| PROJECT NAME | PROJECT ADDRESS | DATE SUBMITTED |
|--------------------------------|--------------------------------------------|----------------|
| CHRIS GIBSON REC CENTRE 23-214 | 125 McLaughlin Rd N, Brampton, ON, L6X 1N9 | Dec 2, 2024 |

| TO | FROM |
|--------------------------------------------|-----------------------------------------------|
| Ashish Singla | INZAMAN KHAN |
| COMPANY | COMPANY |
| RAFAT GENERAL CONTRACTOR INC. | Consult Mechanical Inc. |
| EMAIL | EMAIL |
| asingla@corebuildconstruction.com | inzaman@consultmechanical.com |
| ADDRESS | ADDRESS |
| 8850 GEORGE BOLTON PKWY BOLTON, ON L7E 2Y4 | 54 Audia Court, Unit 2 Concord, ON L4K 3N5 |

Title

EVP-3/CND-2 R1

Description

The specified unit is based on the refrigerant 410A. This new regulation of using the alternate refrigerant is being enforced 'suddenly' within about 6 months time. Canada had once decided not to follow the US to change the new refrigerant as of January 1 2025, and this decision was reversed within recent few months. At the time of tendering the manufacturer did not have information for the new model yet. The supplier provided the pricing of the unit during tender and assumed the unit would be purchased by September this year but that was not the case so alternate is being proposed with no cost impact.

Package Items

| SPEC | SUBSECTION | ITEM | TYPE |
|------|------------|------|------|
|------|------------|------|------|