



54 Audia Court, Unit 2
Concord, ON L4K 3N5
(905)-738-1400

Change Order Quote

Project: CIBC ERIN MILLS
Change Order No.: 24-255-COR004

Date: Oct 8, 2024

Attn

Chanchal Banwait
O.N. SITE CONSTRUCTION INC.
2861 Sherwood Heights Dr Unit 40 Oakville, ON L6J 7K1
Quote Validity: 7 Days

Issued by

MOHAMMED LODHI

Subject: SERVER ROOM AC UNIT REPLACEMENT RECOMMENDED DUE TO EXISTING LEAKING UNIT

Scope of Work:

The unit that was to be relocated was short 1Lb of refrigerant from its factory charge, the indoor unit has notable damaged on the casing, when we reclaimed the refrigerant the system has been contaminated with a dye(likely used to look for existing leak) this substance isn't meant to be left in a system long term, our suggestion is to replace entire system to allow for reliable equipment once this reno is completed.

This would include all new line sets with new indoor/outdoor units complete with commissioning.

Note:

Quote includes Demo and disposable of existing Indoor Unit, Outdoor Unit, line sets, etc.
Amount Quoted does not include Tax, HST will be extra

Description	Qty	Unit	Unit Rate	Amount
Install New indoor and outdoor unit incl. start up and comissioning	24.00	Hrs	130.00	\$3,120.00
Supply New A/C Unit PKA-A18LA1/ PUY-A18NKA7-40	1.00	Each	6,951.00	\$6,951.00
			OH & P	\$1,007.10
			Total	\$11,078.10