

## **Request For Information** 22-001-006

Jan 10, 2025

Project Name Project Address

ENBRIDGE BLDG B 405 Eastern Ave, Toronto, ON, M4M 1B7

To From

Name Name

Ananth Manigandan INZAMAN KHAN

Company

ROCHON BUILDING CORPORATION Consult Mechanical Inc.

Email Email

AManigandan@rochonbuildingcorp.com inzaman@consultmechanical.com

Address

74 INDUSTY STREET TORONTO, ON M6M 4L7 54 Audia Court, Unit 2 Concord, ON L4K 3N5

Title SCHEDULE IMPACT COST IMPACT

Louvers Finish Clarification Probable Probable

**RETURN BY** Jan 16, 2025

## **Information Requested**

The reviewed shop drawings are asking for louvers as an anodized finish for the Basement & Penthouse louvers.

Please note that Ventex colours Ivory V1020 & Charcoal V1022 cannot be provided with an anodized finish, as they are only available as powder coated finishes.

If an anodized finish is required Ventex offers standard options such as Clear, Black, Bronze – light / med / dark or Duranar finish to match. This will be extra to supply.

Please advise!