



54 Audia Court, Unit 2
Concord, ON L4K 3N5
(905)-738-1400

Request For Information 22-001-017

May 8, 2025

Project Name

ENBRIDGE BLDG B

Project Address

405 Eastern Ave, Toronto, ON, M4M 1B7

To

Name

Ananth Manigandan

Company

ROCHON BUILDING CORPORATION

Email

AManigandan@rochonbuildingcorp.com

Address

74 INDUSTY STREET TORONTO, ON M6M 4L7

From

Name

INZAMAN KHAN

Company

Consult Mechanical Inc.

Email

inzaman@consultmechanical.com

Address

54 Audia Court, Unit 2 Concord, ON L4K 3N5

Title

Receptable for condensate pumps power

SCHEDULE IMPACT

Probable

COST IMPACT

Probable

RETURN BY

May 6, 2025

Information Requested

Room 117, 116A, 114A and 132 have fan coil units mounted at 12" above the ceiling as spec'd for maintenance in a recessed cove making it impossible for the drains to be run low enough for their current condensate pumps to make their 22" max rise.

Please advise if the electrical can provide a 120v receptacle at each of these four fan coils so we can mount a stronger condensate pumps.

R. 1: Please add 115v receptacle to fan coil in room 101A as well.