



54 Audia Court, Unit 2
Concord, ON L4K 3N5
(905)-738-1400

Request For Information 22-001-018

May 7, 2025

Project Name

ENBRIDGE BLDG B

Project Address

405 Eastern Ave, Toronto, ON, M4M 1B7

To

Name

Ananth Manigandan

Company

ROCHON BUILDING CORPORATION

Email

AManigandan@rochonbuildingcorp.com

Address

74 INDUSTRY STREET TORONTO, ON M6M 4L7

From

Name

INZAMAN KHAN

Company

Consult Mechanical Inc.

Email

inzaman@consultmechanical.com

Address

54 Audia Court, Unit 2 Concord, ON L4K 3N5

Title

Sump pumps clarification

SCHEDULE IMPACT

Probable

COST IMPACT

Probable

RETURN BY

May 14, 2025

Information Requested

On M-801 Detail#2 & M-802 Detail #1 it shows the pumps as having 3 floats (Alarm, On, Off) only. However on the control panel schematic for the pumps its shows 4 (Alarm, Lag, On, Off) We need to know which way to wire the floats. Also, there were no high water Alarm panels shipped with the package and there is no specific submittal for them but the wiring diagram shows a high water float. Please advise on the way forward.