



54 Audia Court, Unit 2
Concord, ON L4K 3N5
(905)-738-1400

Submittal 22-001-021

PROJECT NAME	PROJECT ADDRESS	DATE SUBMITTED
ENBRIDGE BLDG B 22-001	405 Eastern Ave, Toronto, ON, M4M 1B7	Jun 23, 2025
TO	FROM	
Ananth Manigandan	INZAMAN KHAN	
COMPANY	COMPANY	
ROCHON BUILDING CORPORATION	Consult Mechanical Inc.	
EMAIL	EMAIL	
AManigandan@rochonbuildingcorp.com	inzaman@consultmechanical.com	
ADDRESS	ADDRESS	
74 INDUSTY STREET TORONTO, ON M6M 4L7	54 Audia Court, Unit 2 Concord, ON L4K 3N5	

Title

PC 126: Pressure Washer PW-1

Description

Pressure Washer :

-MX315BXX-8C Industrial strength pressure washer unit is rated for 1500 psi and 3.2 gpm.

-HWG20-N99L-F HWG20 gas fired heater provides 200,000 BTU of heat.

-Options:

-HWX-45 Raised heater stand for HWG40 or HWG20 heaters positions heater above MX pressure washers.

-ELCREM-X1GY/L Remote station consists of sealed enclosure with IP65 rated red, green and yellow pushbuttons with 1N/O contact each. Green and Yellow pushbuttons are illuminated.

- HWG-PV4B-24 Side wall power venter for use with HWG20 heater.

-HWG-PVVH4 Sidewall vent hood for use with HWG-PV4B-24 power venter.

-HWG-AD7 Automatic vent damper reduces heat loss through chimney and assists in protecting heater coil from freezing.

Package Items

SPEC	SUBSECTION	ITEM	TYPE
------	------------	------	------