

Request For Information 25-053-002

Aug 15, 2025

Project Name Project Address

LCBO - 1090 Queensway 1090 The Queensway, Toronto ON M8Z 1P7

To From

Name Name

Harshil Sheth Ray Risto

Company

ROYALTY GENERAL CONSTRUCTION LTD. Consult Mechanical Inc.

Email

hsheth@royaltygeneral.com ray.r@consultmechanical.com

Address

2580 Matheson Blvd E, Suite 201, Mississauga, ON L4W

4J1

54 Audia Court, Unit 2 Concord, ON L4K 3N5

Title SCHEDULE IMPACT COST IMPACT

RTU-2 Curb Installation Vs. Sleepers No Probable

RETURN BY Aug 20, 2025

Information Requested

We propose a manufactured roof curb for the side-discharge RTU-2 instead of existing sleepers. Curbs provide:

Efficiency: Precise duct alignment optimizes airflow.

Weatherproofing: Sealed design prevents leaks.

Structural Integrity: Engineered load distribution ensures stability and code compliance.

Please review and advise for clarification.