

## **Request For Information** 24-252-002

Nov 29, 2024

**Project Name** 

MARTIN REA BUILDING EXPANSION

**Project Address** 

99 Golf Course Line, Ridgetown, ON NOP 2C0

To

Name

**ARUNA** 

Company

RAM DEVELOPMENTS

Email

estimating@ramcon.ca

Address

From

Name

**INZAMAN KHAN** 

Company

Consult Mechanical Inc.

**Email** 

inzaman@consultmechanical.com

Address

54 Audia Court, Unit 2 Concord, ON L4K 3N5

Title SCHEDULE IMPACT COST IMPACT

P-1 overload issue Probable No

**RETURN BY** Nov 29, 2024

## **Information Requested**

Manufacturer recommend 5 HP motor instead of 3 HP mentioned in the approved shops. So that the entire range of the performance curve (refer attached) would be utilized without any motor overload or issue to the pump. Please advise at the earliest to mitigate delays.