



54 Audia Court, Unit 2
Concord, ON L4K 3N5
(905)-738-1400

Request For Information 24-256-001

Jun 16, 2025

Project Name
NESHAMA HOSPICE

Project Address
3 Cadillac Avenue North York, ON M3H 1R9

To

Name
Taranjeet Singh
Company
1568796 ONTARIO INC. C/A RENOKREW
Email
taranjeet@renokrew.com
Address
43 LEPAGE COURT TORONTO, ON M3J 1Z9

From

Name
PAUL LEDDY
Company
Consult Mechanical Inc.
Email
paul.l@consultmechanical.com
Address
54 Audia Court, Unit 2 Concord, ON L4K 3N5

| Title | SCHEDULE IMPACT | COST IMPACT |
|---------------------------|-----------------|-------------|
| Back Water Valve required | Probable | Probable |

RETURN BY

Jun 18, 2025

Information Requested

On Drawing M-10 where the scupper leaves the elevator pit requires a backwater valve. The route we are running the drain will take us through the storage room. We need to know what type of cover they want to use that will be visible on the finished floor. I've attached a picture showing approximate route and location for the backwater valve

Please issue a change to add this valve and spec a cover type, the inspector will require this