



54 Audia Court, Unit 2  
Concord, ON L4K 3N5  
(905)-738-1400

## Change Order Quote

Project: SCARBOROUGH WARMING CENTRE PH2

Date: Feb 20, 2025

Change Order No.: 24-247-COR004

**Attn**

**Issued by**

Taranjeet Singh

MOHAMMED LODHI

1568796 ONTARIO INC. C/A RENOKREW

43 LEPAGE COURT TORONTO, ON M3J 1Z9

Quote Validity: 7 Days

**Subject:** PC.12 Ground Floor Shower & Washroom Heaters

Title: Ground Floor Shower and Washroom Heaters

Reason of Change: To adjust temperature in Washroom and Shower Rooms

Reason for Change: It was reported that Shower and Washroom on Ground floor are too hot. The existing heaters are controlled by a thermostat in the main space and have no means of being controlled individually.

Description of Work:

1. Remove covers and provide thermal insulation over the heaters fins to "block" some of the heat generated in to the room. The insulation length to be adjusted based on the rooms temperature (more insulation if it is too hot and less - if it gets too cold). Re-install covers.

| Description                    | Qty  | Unit | Unit Rate | Amount     |
|--------------------------------|------|------|-----------|------------|
| Re & re cover, wrap insulation | 8.00 | Hrs  | 130.00    | \$1,040.00 |
| Insulation                     | 1.00 | Each | 450.00    | \$450.00   |

---

|  |              |                   |
|--|--------------|-------------------|
|  | OH & P       | \$223.50          |
|  | <b>Total</b> | <b>\$1,713.50</b> |

---