



54 Audia Court, Unit 2
Concord, ON L4K 3N5
(905)-738-1400

Request For Information 24-247-006

Dec 3, 2024

Project Name
SCARBOROUGH WARMING CENTRE PH2

Project Address
885 Scarborough Golf Club Rd Scarborough, ON M1G 1J6

To

Name

Taranjeet Singh

Company

1568796 ONTARIO INC. C/A RENOKREW

Email

taranjeet@renokrew.com

Address

43 LEPAGE COURT TORONTO, ON M3J 1Z9

From

Name

INZAMAN KHAN

Company

Consult Mechanical Inc.

Email

inzaman@consultmechanical.com

Address

54 Audia Court, Unit 2 Concord, ON L4K 3N5

Title

Duct Removal Issue

SCHEDULE IMPACT

Probable

COST IMPACT

Probable

RETURN BY

Dec 4, 2024

Information Requested

Duct was installed inside the ceiling joist, with a wall built in front of it preventing access to disassemble the duct in smaller sections. Duct is 12" wide and the opening from joist to wall is 10". As per demo drawings the duct size is listed as 22"x8". However, in the joist space the dimensions are 16"x12" which indicates that the duct was originally intended to be installed below the joist space, representing an undocumented change on the plan.

To facilitate the removal of this duct, the existing wall will need to be either cut down by 24" or completely removed as it seems the duct was put together on the ground and installed as a single unit.

Please advise on how to proceed.