


- NEW GENERATION BOUTIQUE – CONINGS**
- ✓**M27** PROVIDE QUAD OUTLET FOR WELCOME CORN IN 12" BX WHP IN BASE OF FIXTURE AND HARMONISE COSMETIC FINISHES TO RECEPTACLE IN BASE OF FIXTURE. PROVIDE 12" DOWN FROM TOP FRAME. ELECTRICAL CONTRACTOR SHALL PROVIDE FINAL HOOKUP. FOR QUANTITY OF LIGHTING REFER TO MERCHANDISING PLAN OR DSM. CO-ORDINATE WELCOME CORN LIGHTING FOR CORN BUILT-IN LIGHTING TO BE REUSED FOR NEW FUTURE. REFER TO DRAWING E1 FOR ADDITIONAL INFORMATION.
- ✓**M28** MOUNT DUPLEX RECEPTACLE AT 48" AFF. ON DISPLAY UNIT ASSEMBLY. EXISTING BOUTIQUE END CIRCUIT TO BE REUSED FOR NEW FUTURES. REFER TO DRAWING E1 FOR ADDITIONAL INFORMATION.
- ✓**M29** EXISTING WELCOME CORN CHECKOUT CIRCUITS TO BE REUSED FOR NEW FUTURE. REFER TO DRAWING E1 FOR ADDITIONAL INFORMATION.
- ✓**M30** EXISTING DOWN WALL CIRCUITS TO BE REUSED FOR NEW FUTURES. REFER TO DRAWING E1 FOR MORE INFORMATION. CIRCUITS TO BE DISTRIBUTED EVENLY.
- ✓**M31** EXISTING BOUTIQUE VENDOR WALL CIRCUITS TO BE REUSED FOR NEW FUTURES. REFER TO DRAWING E1 FOR MORE INFORMATION. CIRCUITS TO BE DISTRIBUTED EVENLY.
- ✓**M32** EXISTING BOUTIQUE FRAMANCE CIRCUITS TO BE REUSED FOR NEW FUTURES. REFER TO DRAWING E1 FOR MORE INFORMATION.
- ✓**M33** CONTROLLED LIGHTING CONNECTION FOR MALL CENTER. SEE LOCATION.
- ✓**M34** EXISTING BOUTIQUE VENDOR WALL CIRCUITS TO BE REUSED FOR NEW FUTURES. REFER TO DRAWING E1 FOR MORE INFORMATION. CIRCUITS TO BE DISTRIBUTED EVENLY.
- ✓**M35** RECEPTACLE TO BE MOUNTED ON SIDE OF GONDOLA FIXTURE UPRIGHT, 12" DOWN FROM TOP FRAME.
- ✓**M36** QUAD OUTLET C/W 2 DATA PORTS TO SERVICE DIGITAL SCREEN FOR VENDOR BAYS. CONFIRM LOCATION WITH AOM PROJECT MANAGER PRIOR TO ROUGH-IN.
- ✓**M37** EXISTING REMOTEIS TO BE REUSED FOR NEW FUTURES. REFER TO DRAWING E1 FOR MORE INFORMATION. QUAD RECEPTACLE FOR COSMETIC DISPLAY FIXTURE. EVENLY DISTRIBUTE LIGHTING FIXTURES IN RECEPTACLE IN QUAD CIRCUIT, MAX. 12A PER CIRCUIT. MOUNTING HEIGHT TO BE 85" AFF.
- ✓**M38** 20A RECEPTACLE FOR ORAL/FACIAL CARE DISPLAY. MOUNT RECEPTACLE IN BASE OF GONDOLA IN AN 18" BOX ON 48" BX WHP. CO-ORDINATE EXACT LOCATION OF RECEPTACLE WITH MERCHANDISING PLAN PRIOR TO INSTALLATION.
- FIRE ALARM NOTES**
- ✓**F1** EXISTING FIRE ALARM BELLS TO BE RELOCATED TO NEW CEILING. PROVIDE A VERIFICATION LETTER BY OUR RELATED DESIGNS.
- GENERAL SALES AREA**
- ✓**G1** PROVIDE 120V POWER THRU RACKWAY TO POWER PAK PRE-INSTALLED ON GATE POLE. LOW VOLTAGE WIRING TO RUN THRU RACKWAY TO OTHER POLE. LOW VOLTAGE TO BE PROVIDED BY CONTRACTOR TO OBTAIN GATE CUTOFF-POWER TO COMMERCIAL WORK.
- ✓**G2** PROVIDE AND INSTALL A DUPLEX RECEPTACLE IN AN 18" BOX WITHIN MILLIMETER GABLE ENDS AT (14" AFF.) IN BASE OF THE UNIT. IN ADDITION TO THE 12" DOWN FROM TOP FRAME OF THE UNIT. PROVIDE 12" DOWN FROM WALL TO 18" BOX. FINAL CONNECTION OF ALL UNLIMITED FIXTURES IN READING CENTER BY THE CONTRACTOR. REUSE EXISTING CIRCUIT FROM EXISTING REMODELED RECEPTACLE.
- ✓**G3** PROVIDE A 20A CONNECTION FOR UNLIMITED DISPLAY. PROVIDE AND INSTALL NEW RECEPTACLE IN AN 18" BOX IN BASE OF THE UNIT. IN ADDITION TO THE 12" DOWN FROM TOP FRAME OF THE UNIT.
- ✓**G4** THIS RECEPTACLE IS TO PROVIDE POWER TO NEW EXHAUST FAN. THIS EXHAUST FAN IS TO BE CONTROLLED BY 24V7 THROCKLOC LOCATED IN THE EXISTING ELECTRICAL ROOM. CONTROL TO BE PROVIDED AND INSTALLED BY THE CONTRACTOR CO-ORDINATE WITH MECHANICAL CONTRACTOR.
- ✓**G5** EXISTING SALES AREA GONDOLA CIRCUITS TO BE REUSED FOR NEW FUTURE. REFER TO DRAWING E1 FOR MORE INFORMATION.

No.	DESCRIPTION	DATE
R E V I S I O N S		



1	TENDER	25.04.02
0	PERMIT	25.03.18
No.	DESCRIPTION	DATE
ISSUED FOR		



PROJECT:
ALTERATIONS TO EXISTING
RETAIL BUILDING
SHOPPERS DRUG MART #830
FAIRVIEW MALL
1800 SHEPPARD AVENUE EAST, UNIT 2075

DATE:	DAY: BY:	CHD: BY:
MARCH 2025	SM	PO/CLH

DRAWING TITLE:
ELECTRICAL FLOOR PLAN
- POWER & SYSTEMS

SCALE: 3/16" = 1'-0"	DRAWING No.: E4
PROJ. NO.: 2025-830	