



200 Tesma Way, Unit 9
Concord, ON L4K 0J9
(905)-738-1400

Request For Information 24-247-003

Aug 27, 2024

Project Name

Scarborough Warming Center

Project Address

885 Scarborough Golf Club Rd Scarborough, ON M1G 1J6

To

Name

Taranjeet Singh

Company

1568796 ONTARIO INC. C/A RENOKREW

Email

taranjeet@renokrew.com

Address

43 LEPAGE COURT TORONTO, ON M3J 1Z9

From

Name

INZAMAN KHAN

Company

Consult Mechanical Inc.

Email

inzaman@consultmechanical.com

Address

200 Tesma Way, Unit 9 Concord, ON L4K 0J9

Title

Below Slab Issues

SCHEDULE IMPACT

No

COST IMPACT

No

RETURN BY

Aug 30, 2024

Information Requested

Refer to the attached "Connect to existing" as indicated on the drawing is not feasible as the drain cannot be located. The existing 2" drain that was serving the kitchen sink runs all the way into the washroom area on the other side of the wall and ties in somewhere there. So. the washroom floor will have to be demolished to locate the 4" main. We believe it's either close to one of the toilets or the floor drain located in that washroom.

Please advise and confirm !

Attachments

1. [SSHA-RFI-001-Attachement.pdf](#)