

## **Request For Information** 24-247-004

Sep 10, 2024

Project Name Project Address

Scarborough Warming Center 885 Scarborough Golf Club Rd Scarborough, ON M1G 1J6

To From

Name Name

Taranjeet Singh INZAMAN KHAN

Company

1568796 ONTARIO INC. C/A RENOKREW Consult Mechanical Inc.

Email Email

taranjeet@renokrew.com inzaman@consultmechanical.com

Address Address

43 LEPAGE COURT TORONTO, ON M3J 1Z9 54 Audia Court, Unit 2 Concord, ON L4K 3N5

Title SCHEDULE IMPACT COST IMPACT

UNIVERSAL WASHROOM WALLS Probable Probable

**RETURN BY** Sep 14, 2024

## **Information Requested**

Issue: The detail drawing (A5.0) shows that all washrooms walls are 8" concrete masonry walls (PW3). We have a shower valve, plumbing waterlines , vent pipe and HVAC vents that need to be installed where the block walls are. we are not able to mount a shower valve etc in a block wall .

Request: Please advise or have the bathroom framed with metal studs and drywall or furred/strapped to accommodate plumbing. We our requesting for the shower faucet wall as well as the universal washroom wall.