



54 Audia Court, Unit 2
Concord, ON L4K 3N5
(905)-738-1400

Change Order Quote

Project: TD TIMMINS

Date: Nov 25, 2024

Change Order No.: 24-258-COR001

Attn

Issued by

Brendan Neglia

MOHAMMED LODHI

O.N. SITE CONSTRUCTION INC.

2861 Sherwood Heights Dr Unit 40 Oakville, ON L6J 7K1

Quote Validity: 15 Days

Subject: CCO 10R1 for washroom exhaust fan and connections

Scope of Work:

1 Refer to drawing M2.0, HVAC Demolition & New (drawing not issued here within):

1.1 In existing washroom, provide new ceiling mounted washroom exhaust fan 'EF-2' and connect to existing

flexible 4" washroom exhaust air duct in ceiling space. New exhaust fan 'EF-2' to read 'Greenheck SP-B70 or

equal, complete with (14 7/8"x 13 1/4") 'designer grille'. 675 rpm, 120/1/60. Sones 1.4, 55 cfm at 0.25 inches

wg'. New exhaust fan cut sheet as enclosed. Fan to be controlled by the existing lighting switch in the space.

Electrical to provide power.

1.2 In the adjacent space, reconnect broken 4" exhaust air duct for this washroom.

Reason for PC:

Field Condition

Exclusions:

All work related to enable installation of fan and its connection related to other trades like electrical, drywall, ceiling, etc.

Electrical power hook up

Note:

Lead time for fan 2-1/2 weeks from date of release.

Cost for rush delivery added

Amount quoted does not include tax. HST will be extra.

Description	Qty	Unit	Unit Rate	Amount
Installation and connection of new exhaust fan, reconnection of broken exhaust duct in adj. room	4.00	Hrs	130.00	\$520.00
1x SP-B70 - 54 cfm @ .25" c/w speed controller	1.00	Each	763.00	\$763.00
Rush Delivery	1.00	Each	120.00	\$120.00
			OH & P	\$140.30
			Total	\$1,543.30