



54 Audia Court, Unit 2
Concord, ON L4K 3N5
(905)-738-1400

Request For Information 24-280-001

Feb 27, 2025

Project Name
VICTORIA PARK ARENA

Project Address
20 Victoria Crescent, Brampton, ON L6T 1E4

To

Name
Abdullah Hissamuddin
Company
RAFAT GENERAL CONTRACTOR INC.
Email
abdullah.hissam@rafat.ca
Address
8850 GEORGE BOLTON PKWY BOLTON, ON L7E 2Y4

From

Name
INZAMAN KHAN
Company
Consult Mechanical Inc.
Email
inzaman@consultmechanical.com
Address
54 Audia Court, Unit 2 Concord, ON L4K 3N5

Title	SCHEDULE IMPACT	COST IMPACT
Frost control clarification for Electric Duct Heaters EBC-1,2,3 (23 82 39)	No	Probable

RETURN BY

Mar 4, 2025

Information Requested

In response to the engineer's comment regarding the justification on frost control in the reviewed submittal (attached). We want to clarify that the frost control is actually included which is the thermostat (model CTH291) that will get mounted and wired to the 0-10vdc terminal block on the heater. They will set the temperature on the stat accordingly.
Please confirm or advise if this is approved/suitable. If more specific control is required it'll need to be confirmed through a site instruction.