



54 Audia Court, Unit 2
Concord, ON L4K 3N5
(905)-738-1400

Request For Information 24-277-013

Feb 18, 2025

Project Name

YORK REGION VARIOUS PROJECTS

Project Address

17250 Young Street Newmarket, ON

To

Name

Tom Butkovic

Company

TRISECT CONSTRUCTION

Email

tbutkovic@trisectconstruction.com

Address

4020A SLADEVIEW cRESCENT, UNIT 7 MISSISSAUGA,
ON L5L 6B1 JOB: 1300 INSLINGTON SUITE 103

From

Name

PAUL LEDDY

Company

Consult Mechanical Inc.

Email

paul.l@consultmechanical.com

Address

54 Audia Court, Unit 2 Concord, ON L4K 3N5

Title

Interference with Condensate Drains

SCHEDULE IMPACT

No

COST IMPACT

No

RETURN BY

Feb 18, 2025

Information Requested

the tie in point for the condensate drains. It says on drawing M-305 :Note: 5 we have to connect the condensate drains on the vertical. For this to happen we will need the drywall removed behind every pillar in order to make this connection and cut in a wye. We have the space to connect on the horizontal if they will allow us to before the turn down behind the drywall.

Please advise.