



54 Audia Court, Unit 2
Concord, ON L4K 3N5
(905)-738-1400

Request For Information 24-277-024

May 21, 2025

Project Name

YORK REGION VARIOUS PROJECTS

Project Address

17250 Young Street Newmarket, ON

To

Name

Tom Butkovic

Company

TRISECT CONSTRUCTION

Email

tbutkovic@trisectconstruction.com

Address

4020A SLADEVIEW cRESCENT, UNIT 7 MISSISSAUGA,
ON L5L 6B1 JOB: 1300 INSLINGTON SUITE 103

From

Name

PAUL LEDDY

Company

Consult Mechanical Inc.

Email

paul.l@consultmechanical.com

Address

54 Audia Court, Unit 2 Concord, ON L4K 3N5

Title

Pressure Differentials

SCHEDULE IMPACT

Probable

COST IMPACT

Probable

RETURN BY

May 28, 2025

Information Requested

The drawings indicates pressure differential requirements as per note #11. There seems to be a total of 5 required for the heating although the drawing does not show any on the chilled piping? Generally this is a function to protect the pumps.

If this is the intent to only have the PD's on the heat can the consultant confirm. If required now would be the time as the system is empty.