

REQUEST FOR INFORMATION

Date: June 26, 2025

Trisect Project No: TC24-114

Project Name: York Region Admin., Package D Renovation

CONSULTANTS RFI NO: TC24-114-52-X

REFERENCE: Fresh Air Duct, Third Floor			
Spec. Section:			
Drawing No.(s):			
Attachments:			
ural Mechanical Electrical			
RESPONSE/INFORMATION REQUIRED BY: June 30, 2025			

On behalf of the mechanical subcontractor, please review and reply to the following:

Information Requested

can tie into the existing duct that was serving the forth floor and is now abandoned this would save us from having to scan, and core and also run the duct down to the second floor and eliminating the fire damper

GPY Response: As discussed on the meeting. Please ensure that the 18"x12" existing main outdoor air supply duct riser is active before connecting the new Booster Fan BF-3.1. Based on the size of the duct, it can accomodate the required ventilation air of 220 cfm. Please reflect this deviation on the as-built drawings.

