

## **Submittal 24-277-008**

PROJECT NAME PROJECT ADDRESS DATE SUBMITTED

YORK REGION VARIOUS PROJECTS 24-277 17250 Young Street Newmarket, ON Jan 14, 2025

TO FROM

Tom Butkovic INZAMAN KHAN

COMPANY

TRISECT CONSTRUCTION Consult Mechanical Inc.

EMAIL EMAIL

tbutkovic@trisectconstruction.com inzaman@consultmechanical.com

ADDRESS ADDRESS

4020A SLADEVIEW cRESCENT, UNIT 7 MISSISSAUGA, ON L5L 6B1 54 Audia Court, Unit 2

JOB: 1300 INSLINGTON SUITE 103 Concord, ON L4K 3N5

## Title

WC-1 & WC-2 flush valve R.1

## **Description**

Please refer to the suppliers comment below and confirm:

The chosen WC1 & WC2 fixture is Afwall TS Bowl so you can use Base Model TS FV # 606B121.002 (1.28 gpf) with Hard Wired AC adapter # PK01.HAC. I have attached the spec of both the FV and power pack separately. Alternatively you can also choose any of the flow rates (1.6 or 1.1 gpf based on site requirement, all flow rates are indicated on spec sheet).

## **Package Items**

SPEC SUBSECTION ITEM TYPE